IAC Ch 60, p.1

481—60.9(135C) Definition of public area. The size of the public area shall depend upon the number and types of beds within the supervised unit. A public area shall contain the following rooms or areas: (III)

- **60.9(1)** A vestibule area equipped with coat rack and shelf shall be available. (III)
- **60.9(2)** A public telephone shall be accessible to the residents within the facility to make personal calls. (III)
 - **60.9(3)** Drinking fountains shall be available. (III) (Exception 1)
 - **60.9(4)** Every facility shall provide a separate toilet for the public, with a lavatory and water closet.
- a. Each facility of eight beds or less shall designate a toilet, with lavatory and water closet for public use.
- b. Public toilets shall be accessible to and usable by the physically handicapped, equipped with appropriate equipment installed to meet the American Standards National Document A 117.1-1986. (III) (Exception 3)
- c. In facilities over 15 beds, there shall be public facilities for both men and women. (III) (Exception 4)
- d. Public facilities for both men and women must contain a clear floor area free from obstructions of 60 inches in diameter. (Exception 3)